



May 3, 2002

*******ADDENDUM*********ADDENDUM*******

BID NUMBER: RF2182

DUE DATE : 05/09/02

ADDENDUM #2: RF2182AD2

DESCRIPTION: NEW OR USED UPS SYSTEM

Please add the following to the specifications:

1. Voltage in is 208, 3 phase; voltage out is 208, 3 phase.
2. Capacity of the battery bank is to be 12 minutes, minimum, at full rated load.
3. Please change the ship to address from 1110 State Office Bldg. to the following: **CEM South Building, Camp Williams, 17800 Camp Williams Road Riverton, Utah 84065**. Point of Contact at the site is Ms. Karen Jensen, 801 302-5309.
4. Installation includes necessary wiring of the UPS into the electrical system of the building.
5. The bid due date remains the same.

To acknowledge receipt of addendums, either include a copy of addendum with bid submittal or give written acknowledgement with bid. It shall be the responsibility of the bidder to appropriately disseminate this information to all concerned prior to the assigned bid time.

Signature

Date

Company Name